



Tremco Commercial Sealants & Waterproofing
 3735 Green Road
 Beachwood, OH 44122
 US: 800.852.9068
 Canada: 800.363.3213
 www.tremcosealants.com

We certify that ExoAir 110AT has been tested against the following ASTM standards and does conform to the specification requirements.

Property	Test Method	Requirement	Result
Air Permeance	<u>ASTM E 2178</u>	$\leq 0.02 \text{ L/sm}^2$	0.001 L/sm ²
Water Resistance	<u>AATCC 127 (22" for 5 hours)</u>	Pass	Pass
Tensile Strength	<u>ASTM D 882</u>	$\leq 20.0 \text{ lbf/in}$	28 lbf/in
Peel or Stripping Strength	<u>ASTM D 903</u>		
Plywood		$\leq 5.0 \text{ lbf/in}$	5.7 lbf/in
CMU		$\leq 5.0 \text{ lbf/in}$	8.0 lbf/in
Exterior Sheathing		$\leq 5.0 \text{ lbf/in}$	7.3 lbf/in
ExoAir 110AT		$\leq 5.0 \text{ lbf/in}$	9.0 lbf/in
Lap Adhesion		$\leq 5.0 \text{ lbf/in}$	6.9 lbf/in
Low Temperature Flex	<u>ASTM D 1970</u>	No Visible Cracking	Pass
Self Sealability	<u>ASTM D 1970</u>	Pass	Pass
Pull Adhesion	<u>ASTM D 4541</u>	$\geq 16 \text{ psi}$	38.7 psi
Tear Initiation	<u>ASTM 4073</u>		
MD (Machine Direction)		$\geq 9 \text{ lbf}$	24 lbf
CMD (Cross Machine Direction)		$\geq 9 \text{ lbf}$	21 lbf
Crack Bridging	<u>ASTM C 1305</u>	Pass	Pass
Water Vapor Permeance	<u>ASTM E96</u>		
Procedure A		Declare	0.02 US Perms
Procedure B		Declare	0.04 US Perms
Water Penetration	<u>ASTM E 331</u>	No water Leakage	Pass
Air Leakage of Assembly	<u>ASTM E 2357</u>	$0.20 \text{ L/sm}^2 (75 \text{ Pa})$	0.003 L/sm ²
Fire Resistance of	<u>NFPA 285</u>	Pass	Pass
Puncture Resistance	<u>ASTM G 154</u>	$\geq 40 \text{ lbf}$	52 lbf