

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
WILLIAM J. ROUSE
PRESIDENT
EFREN ABRATIQUÉ, P.E.
VICE-PRESIDENT
MARSHA L. BROWN
ILAN ISRAELY
JAVIER NUÑEZ
—

CITY OF LOS ANGELES
CALIFORNIA



JAMES K. HAHN
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER
—

Tremco, Incorporated
3735 Green Road
Beachwood, OH 44122

Attn: Wes Hensley
(216) 766-5531

RESEARCH REPORT: RR 24174
(CSI #07920)

Expires: April 1, 2009

GENERAL APPROVAL -Renewal/Clerical Modification - Vulkem Urethane Sealants and Membrane Materials.

DETAILS

Gun-grade Sealants. Vulkem 116 and 227 are intended for use as a resilient setting material for glazing and for use as a waterproofing sealant at wall joints below grade as required by Section 1402.4 of the 2002 Los Angeles City Building Code.

Self-leveling Sealants. Vulkem 45 and 245 are intended for use as waterproof seals for swimming pool coping in expansive soils areas as required by Information Bulletin No. P/BC 2001-14. Vulkem 202 is for jet-fuel resistant applications such as at airport loading areas and maintenance yards.

Membranes. TREMproof 201/60 and 222 are intended for use in basement walls and as split slab waterproofing and in planters as required by Section 1402.4 and 1402.5 of the 2002 Los Angeles City Building Code. Vulkem 345, 346, 350, and 351 are intended for use as a waterproofing membrane for decks on balconies, but are not approved for use as a roof covering material.

The approval is subject to the following conditions:

1. Each container for the sealants and membranes shall be labeled Tremco Incorporated in gold/black foil on the gun-grade sealants, while other containers are blue, lithographed pails.

RR 24174
Page 1 of 2

Tremco Incorporated

RE: Vulkem Urethane Sealants & Membrane Materials

2. The products shall be used in accordance with the manufacturer's instructions and Building Code requirements.
3. Installation shall be in accordance with the manufacturer's written instructions and as specified herein. A copy shall be kept at the job site.


DISCUSSION

The clerical modification is to change TREMproof 201 to TREMproof 201/60.

The conditions set forth above are only applicable where the particular uses of the sealants and membranes are regulated by the 2002 Los Angeles City Building Code.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.



YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

*U*YC:elem
RR24174/wpd8.0
R03/05/07
2H6/4B/1402.1/2404

RR 24174
Page 2 of 2